



## Transmitter Calibration (CR18) Certificate of Conformance

**Date:** 10-10-17  
**Certificate Number:** CR18\_830975

**Customer:**  
**Customer PO:**  
**Reference Customer:**

**Burns Order Number:** SP00003966  
**Burns Order Line:** 2  
**Burns Model Number:** T51(-70 TO 40)C/TT03/CR18/HD02C01  
**Quantity:** 10

**Transmitter Temperature Range:**


Below is a table of the transmitter serial numbers and the matching tag numbers.

Transmitter Serial Number(s)	Tag Numbers(s)
171425654	
171425649	
171425651	
171425397	
171425652	
171425396	
171425653	
171425655	
171425398	
171425650	

The transmitters provided under the referenced order have been set to the temperature range noted above. The transmitter output has been verified at the 0% of span and 100% of span points to be within the limits reported below.

**100% of span:** 4.000± .029 mA

**0% of span:** 20.000± .029 mA

**Date:** 10/10/17  
**Authorized Representative:**  
  
Terry Walsh  
Metrology Technician